

				E. coli (vann) <1 >201 /MPN/100 ml	
				E. coli	Koliforme
Eurofins oppdragsmerking	Eurofins prøvenummer	Prøvemerkning	Prøvemerkning 2	MPN/100 ml	MPN/100 ml
EUNOBE-00068439	441-2023-0929-012	Fossen VPS		<1	<1
EUNOBE-00068439	441-2023-0929-013	Rambergsvegen 16		<1	<1
EUNOBE-00068439	441-2023-0929-014	Rambergsvegen 71		<1	<1

Kunde	Analyserapport	Prøvetakingsdato	Eurofins prøvenummer	Eurofins oppdragsmerking	Prøvemerkning	Prøvemerkning 2	Prøvetype	Test	Parameter	Resultat	Enhet	LOQ	MU
Osterøy kommune	AR-23-MX-025619-01	29-09-2023	441-2023-0929-012	EUNOBE-00068439	Fossen VPS		Drikkevann	Koliforme-E. coli (vann) <1 >201 /MPN/100 ml (0) ISO 9308-2	E. coli	<1	MPN/100 ml		
Osterøy kommune	AR-23-MX-025619-01	29-09-2023	441-2023-0929-012	EUNOBE-00068439	Fossen VPS		Drikkevann	Koliforme-E. coli (vann) <1 >201 /MPN/100 ml (0) ISO 9308-2	Koliforme	<1	MPN/100 ml		
Osterøy kommune	AR-23-MX-025620-01	29-09-2023	441-2023-0929-013	EUNOBE-00068439	Rambergsvegen 16		Drikkevann	Koliforme-E. coli (vann) <1 >201 /MPN/100 ml (0) ISO 9308-2	E. coli	<1	MPN/100 ml		
Osterøy kommune	AR-23-MX-025620-01	29-09-2023	441-2023-0929-013	EUNOBE-00068439	Rambergsvegen 16		Drikkevann	Koliforme-E. coli (vann) <1 >201 /MPN/100 ml (0) ISO 9308-2	Koliforme	<1	MPN/100 ml		
Osterøy kommune	AR-23-MX-025621-01	29-09-2023	441-2023-0929-014	EUNOBE-00068439	Rambergsvegen 71		Drikkevann	Koliforme-E. coli (vann) <1 >201 /MPN/100 ml (0) ISO 9308-2	E. coli	<1	MPN/100 ml		
Osterøy kommune	AR-23-MX-025621-01	29-09-2023	441-2023-0929-014	EUNOBE-00068439	Rambergsvegen 71		Drikkevann	Koliforme-E. coli (vann) <1 >201 /MPN/100 ml (0) ISO 9308-2	Koliforme	<1	MPN/100 ml		