

---

**Fra:** Thy Pham <THPH@cowi.com>  
**Sendt:** 15. september 2017 15:49  
**Til:** Postmottak Lindås; Atle Dingen; Arne Helgesen  
**Kopi:** Johan Stenstrand (johan.stenstrand@skanska.no); Ole Johnny Sølberg;  
Tingvoll Jan Tore (Bravida)  
**Emne:** Søknad for nytt VAO-anlegg for Knarvik barneskule  
**Vedlegg:** Knarvik Barneskule VA.zip; Godkjent VA rammeplan(1).pdf

Hei,

Oversender som følger tegninger over nytt VA-anlegg for Knarvik barneskule med tilhørende detaljer for kommunalt gjennomsyn.

Grunnlaget for det prosjekterte anlegget er fra den godkjente VA-rammeplanen fra 07.02.2017.

For viderøringen av stikkrennen er det valgt betong fremfor DV-rør grunnet større overdekning. Ber om at tilbakemeldinger gjøres via. epost.

Ring meg gjerne om noe skulle være uklart.

Ha en fin helg!

Med vennlig hilsen

**Thy Pham**

VA-Ingeniør  
Region Kyst - divisjon Vann og Miljø

**COWI**

Organisasjonsnummer.: 979 364 857  
Solheimsgt. 13  
5058 Bergen  
Norway

Mobile: +47 48 11 41 04

Email: [thph@cowi.com](mailto:thph@cowi.com)

Website: [www.cowi.no](http://www.cowi.no)

Print only if necessary

This email including attachments, if any, may contain confidential information and is intended solely for the recipient(s) stated above. If you are not the intended recipient please contact the sender by a reply email and delete this email without producing, distributing or retaining copies hereof.