
Fra: Thy Pham <THPH@cowi.com>
Sendt: 20. september 2017 13:09
Til: Postmottak Lindås; Atle Dingen; Arne Helgesen
Kopi: Johan Stenstrand (johan.stenstrand@skanska.no); Ole Johnny Sølberg; Tingvoll Jan Tore (Bravida)
Emne: RE: Søknad for nytt VAO-anlegg for Knarvik barneskule
Vedlegg: VA731-UT-011.pdf; VA73-UT-001.pdf; VA73-UT-002.pdf

Hei,

Viser til tlf. samtale tidligere i dag.

Vedlagt foreligger reviderte tegninger som etterspurt.

- Vannkum V1 er endret til hydrant HY2
- Stengeventil for hydrant er utgått. Brannventil er redusert fra DN100 til DN80 med en flensehøyde til terreng på omtrentlig 10 cm.

Skulle det være noe mer er bare å ringe.

Med vennlig hilsen

Thy Pham

VA-Ingeniør
Region Kyst - divisjon Vann og Miljø

COWI

Organisasjonsnummer.: 979 364 857
Solheimsgt. 13
5058 Bergen
Norway

Mobile: +47 48 11 41 04

Email: thph@cowi.com

Website: www.cowi.no

Print only if necessary

This email including attachments, if any, may contain confidential information and is intended solely for the recipient(s) stated above. If you are not the intended recipient please contact the sender by a reply email and delete this email without producing, distributing or retaining copies hereof.

From: Thy Pham

Sent: Friday, September 15, 2017 3:49 PM

To: postmottak@lindas.kommune.no; atle.dingen@lindas.kommune.no; arne.helgesen@lindas.kommune.no

Cc: Johan Stenstrand (johan.stenstrand@skanska.no) <johan.stenstrand@skanska.no>; Ole Johnny Sølberg <ojsl@cowi.com>; Tingvoll Jan Tore (Bravida) <Jan.Tore.Tingvoll@bravida.no>

Subject: Søknad for nytt VAO-anlegg for Knarvik barneskule

Hei,

Oversender som følger tegninger over nytt VA-anlegg for Knarvik barneskule med tilhørende detaljer for kommunalt gjennomsyn.

Grunnlaget for det prosjekterte anlegget er fra den godkjente VA-rammeplanen fra 07.02.2017.

For viderøringen av stikkrennen er det valgt betong fremfor DV-rør grunnet større overdekning. Ber om at tilbakemeldinger gjøres via. epost.

Ring meg gjerne om noe skulle være uklart.

Ha en fin helg!

Med vennlig hilsen

Thy Pham

VA-Ingeniør

Region Kyst - divisjon Vann og Miljø

COWI

Organisasjonsnummer.: 979 364 857

Solheimsgt. 13

5058 Bergen

Norway

Mobile: +47 48 11 41 04

Email: thph@cowi.com

Website: www.cowi.no

Print only if necessary

This email including attachments, if any, may contain confidential information and is intended solely for the recipient(s) stated above. If you are not the intended recipient please contact the sender by a reply email and delete this email without producing, distributing or retaining copies hereof.